

State Water Resources Control Board

November 14, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 6007

Mr. Armando Plata
Facilities Maintenance Contracts Administrator
Facilities Management
Santa Monica Public Safety Facility
2500 Michigan Avenue
Santa Monica, California 90404
armando.plata@smgov.net

**SUBJECT: FAILURE TO COMPLY; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT SANTA MONICA PUBLIC SAFETY FACILITY, 333 OLYMPIC
DRIVE, SANTA MONICA**

Dear Mr. Plata:

As of the date of this letter, the State Water Resources Control Board (State Water Board) has not received a complete response to our August 28, 2018 Notice of Violation (NOV)(attached). You are directed to correct the ongoing violations identified in the NOV and submit compliance documentation to the State Water Board and Santa Monica Fire Department within ten (10) days from the date of this letter.

Please send all compliance documentation to the following:

State Water Board

Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov

Local CUPA

Ms. Monica Hanley
Environmental Compliance Specialist
Santa Monica Fire Department
333 Olympic Drive, 2nd Floor
Santa Monica, California 90401
monica.hanley@smgov.net

Failure to comply with this notice may result in an enforcement action by the State Water Board. The State Water Board reserves the right to bring an action against the owner and/or operator of the tank(s) in violation, or it may recommend that Santa Monica Fire Department pursue enforcement, or Santa Monica Fire Department may elect to pursue enforcement independently.

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

1001 I Street, Sacramento, CA 95814 | Mailing Address: P.O. Box 100, Sacramento, CA 95812-0100 | www.waterboards.ca.gov

If you have any questions, please contact me at (916) 341-5891, or by email at matthew.buffleben@waterboards.ca.gov.

Sincerely,

A handwritten signature in blue ink that reads "Matthew D. Buffleben".

Dr. Matthew Buffleben
Supervising Water Resource Control Engineer
Acting Supervisor, UST Enforcement Unit
Office of Enforcement

Attachment: August 28, 2018 Notice of Violation

cc: *(via email only)*

Ms. Monica Hanley
Environmental Compliance Specialist
Santa Monica Fire Department
monica.hanley@smgov.net

Mr. David Tu
Water Resources Protection Specialist
Water Resources Protection Programs
City of Santa Monica
david.tu@smgov.net



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

August 30, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 5017

Mr. Armando Plata
Facilities Maintenance Contracts Administrator
Facilities Management
Santa Monica Public Safety Facility
2500 Michigan Avenue
Santa Monica, California 90404
armando.plata@smgov.net

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT SANTA MONICA PUBLIC SAFETY FACILITY, 333 OLYMPIC
DRIVE, SANTA MONICA**

Dear Mr. Plata:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on August 15, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Monitoring or Testing Records – The 2017 and 2016 annual monitoring certification records were not available at the time of inspection.	Diesel	August 15, 2018	Ongoing	H&SC 25293; 23 CCR 2712(b)
2	Failure to Maintain Operating Permit Onsite – A copy of the current operating permit was not available at the time of inspection.	Diesel	August 15, 2018	Ongoing	H&SC 25284(a); 23 CCR 2712(i)
3	Failure to Maintain Financial Responsibility – The Chief Financial Officer letter observed at the time of inspection was not current.	Diesel	August 15, 2018	Ongoing	H&SC 25292.2; 23 CCR 2711(a)(11)

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

1001 I Street, Sacramento, CA 95814 | Mailing Address: P.O. Box 100, Sacramento, CA 95812-0100 | www.waterboards.ca.gov

No.	Violation	Tank	Start Date	Stop Date	Regulation
4	Failure to Maintain Monitoring or Testing Records – The May and June 2018 monthly designated operator inspection reports were not available at the time of inspection.	Diesel	August 15, 2018	Ongoing	23 CCR 2715(e)
5	Failure to Maintain Tank Information – Under tank construction in CERS, primary containment lists fiberglass; however, the Modern Welding tank has a steel primary.	Diesel	August 15, 2018	Ongoing	23 CCR 2711(a)
6	Failure to Maintain Spill Containment Requirements – The April 19, 2018 Annual Monitoring Certification Spill Bucket Testing Report notes that the diesel spill container holds four gallons.	Diesel	April 19, 2018	Ongoing	23 CCR 2635(b)(1)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Santa Monica Fire Department within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov


Local CUPA

Ms. Monica Hanley
Environmental Compliance Specialist
Santa Monica Fire Department
333 Olympic Drive, 2nd Floor
Santa Monica, California 90401
monica.hanley@smgov.net

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: See next page.

cc: *(via email only)*

Ms. Monica Hanley
Environmental Compliance Specialist
Santa Monica Fire Department
monica.hanley@smgov.net